

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No. 187Dated: 23.12.2025

It is certified that an inspection team headed by Shaguyta Anjum
(Name of Officers with designation) from Chemist, Laboratory PHED Vidisha
PHED inspected the **Magadham Vidyapeeth, Teelakhedi - Bypass Road, Teelakhedi, Vidisha MP** on
22.12.25 and on the basis of Water Test Report (Attached) bearing no. 187-23/12/25
dated 23/12/25 of _____ (PHED Lab)

certified that the **Magadham Vidyapeeth, Teelakhedi - Bypass Road, Teelakhedi, Vidisha MP** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 22.12.2026

Signature with seal :-

Name :-

Designation :-

Name & address of the office/Department: -

रसायनज्ञ
जिला जल परीक्षण प्रयोगशाला
मो. स्वास्थ्य सचिवालय विदिशा

To,

Magadham Vidyapeeth,**Teelakhedi - Bypass Road, Teelakhedi, Vidisha MP**

(Name and address of the institution)

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies



DISTRICT WATER TESTING LABORATORY PHED Division VIDISHA

Near Ramlila Maidan Drainage colony Mandi road Vidisha -464001

Test Report



Desp. No. 187

Date 23.12.2025

Report No 187 Date 23.12.2025

A Name and address

Principal Magadham Vidyapeeth
Teelakhedi Vidisha

2. Particulars of a sample place of collection & Details

B Reference No. Nil Dated 23.12.2025
 3 Date and Time of sample receive 23.12.25
 4 Date of analysis start 23.12.25
 3 Date of analysis end 23.12.25
 4 Unique ID 2655
 5 Condition of the sample Ok/Not Ok OK

2655	Inside School Campus - Tap Water

S.No.	Name of parameter	Name of test methods used	BIS 10500:2012 Reaffirmed in Sep. 2018		Unit	Unique ID					
			desireble limits	Permissible limits		2655					
1	Tempraturte	Celsius			Degree C	25C					
2	Turbidity	part 10	1	5	NTU	1.00					
3	Colour	part 04	5	15	Hazon Scale	Nil					
	Taste	Part 7, 8	Agreeable	Not Agreeabl	None	Agreeable					
4	Odour	part 05	Agreeable	Not Agreeabl	None	Agreeable					
5	pH	Part 11	6.5 -8.5	No relax.	pH Scale	7.18					
6	Conductivity	Part 16			Micromho/cm	350					
7	Total solids	Part 16	500	2000	Mg/L	206					
8	Total Alkalinity	Part 23	200	600	Mg/L	109					
9	Total Hardness as Caco3	Part 21	200	600	Mg/L	142					
10	Ca as Ca++	Part 40	75	200	Mg/L	32					
11	Mg as Mg++	Part 46	30	100	Mg/L	14					
12	Chloride	Part 32	250	1000	Mg/L	54					
13	Nitrate as No3	Part 34	45	45	Mg/L	2.50					
14	Iron	Part 53	0.3	0.3	Mg/L	0.11					
15	Fluoride	Part 60	1	1.5	Mg/L	0.25					
16	Sulfate	Part 24	200	400	Mg/L	2.60					
17	Magnese	Part 59	0.1	0.3	Mg/L	Nil					
18	Arsenic	Part 37	0.01	0.05	Mg/L	Nil					
19	Feacal coliform	Part 10	0/100	0/100	per 100 ml	0.00					
20	Total coliform	Part 10	0/100	0/100	Per 100 ml	0.00					

- Note : 1 Sample has been provided by the customer and Sample tested as received.
 2 The result applied to sample as received.
 3 Report shall not be reproduce except in full without approval of the laboratory.
 4. Sample will be retained for 15 days.

Signature of analyst
 District water testing laboratory Vidisha (M.P.)



Shagun Anjum
Shagun Anjum
 Authorised Signatory
 District Water testing laboratory, Vidisha (M.P.)